# GENERAL NOTES: 1. DIMENSIONS

- SHOWN IN INCHES W/ MM EQUIVALENTS IN BRACKETS
- OVERALL LENGTH = CENTERS + FLOAT LENGTH + MATING FLANGE THICKNESS + 6.125" [156]

• MAX PRESSURE, MAX TEMPERATURE, & MIN SPECIFIC GRAVITY REQUIRED FOR PROPER GAGE

• CONSULT "MAGNICATOR® MAGNETIC LIQUID LEVEL INDICATION PRODUCTS" (BULLETIN M100.01) FOR COMPLETE PART NUMBER DETAILS & LIST OF AVAILABLE OPTIONS

### 4. STANDPIPE SIZE

- 2 ½" [65] SCH. 40 (STANDARD)
- CONSULT FACTORY FOR OPTIONAL STANDPIPE SIZE AND/OR SCHEDULE (DEPENDENT ON OPERATING CONDITIONS)

#### 5. MATERIALS OF CONSTRUCTION

- 304/304LSS W/ CS TRIM (CAP, FLANGES, BOLTING, & PLUGS) (STANDARD)
- 316/316LSS W/ CS TRIM (CAP, FLANGES, BOLTING, & PLUGS) (STANDARD)
- ALL 304/304LSS (316SS BOLTING) (STANDARD)
- ALL 316/316LSS (316SS BOLTING) (STANDARD)
- CONSULT "MAGNICATOR® MAGNETIC LIQUID LEVEL INDICATION PRODUCTS" (BULLETIN M100.01) FOR A COMPLETE LIST OF AVAILABLE MATERIALS

#### 6. FLOAT MATERIALS

- 316LSS (STANDARD)
- TITANIUM (STANDARD)
- MONEL 400
- HASTELLOY C276

#### 7. FLOAT LENGTHS

- 12" [305] (STANDARD)
- 17" [432] (STANDARD)
- 22" [559] (STANDARD)
- LENGTHS DEPENDENT ON OPERATING CONDITIONS
- CONSULT FACTORY FOR CUSTOM LENGTHS

#### 8. GASKET MATERIALS

- FLEXITALLIC "CGI" (OR EQUAL) SPIRAL-WOUND (STANDARD) W/ CS OUTER RING, 304 OR 316SS INNER RING, & GRAPHITE FILLER
- CONSULT FACTORY FOR OPTIONAL GASKET MATERIALS

#### 9. PROCESS CONNECTIONS

- 1/2" [15] THRU 1" [25] FNPT & MNPT (STANDARD)
- 1 ½" [40] THRU 6" [150] FNPT & MNPT AVAILABLE ON REQUEST (REQUIRE FITTINGS THAT INCREASE SECTION A-A DIMENSION SHOWN)
- (2) SIDE CONNECTIONS (STANDARD)
- (2+) SIDE CONNECTIONS AVAILABLE ON REQUEST

### 10. VENT / DRAIN CONNECTIONS

- 1/2" [15] FNPT (SHOWN) (STANDARD)
- ½" [15] THRU 1 ½" [40] FNPT, MNPT, FSW, & MSW
- 1/2" [15] TO 3" [80] RAISED-FACE ANSI/ASME & DIN FLANGED

#### 11. INDICATION

- YELLOW / BLACK FLAGS IN ALUMINUM HOUSING (SHOWN) (STANDARD)
- HERMETICALLY-SEALED FLAGS IN POLYCARBONATE TUBE W/ 316SS FRAME (BULLETIN M100.110)
- HERMETICALLY-SEALED FLAGS IN GLASS TUBE W/ 316SS FRAME (BULLETIN M100.110)
- NIGHTSTAR™ (ILLUMINATED FLAGS) (120 OR 240 VAC)(BULLETIN M100.140)


- FEET / INCHES (SHOWN) (STANDARD)
- METER / MILLIMETER
- PERCENT
- CONSULT FACTORY FOR SPECIAL SCALES

### 13. POINT LEVEL SWITCHES


- SAS-16 TRI-MAGNET (BULLETIN M100.27)
- RS-2 (SPDT) HERMETICALLY-SEALED REED (BULLETIN M100.20)
- RS-2/2 (DPDT) HERMETICALLY-SEALED REED (BULLETIN M100.20)

#### 14. 4-20mA TRANSMITTERS

- MTII-4300 MAGNETOSTRICTIVE (BULLETIN M100.23)
- RST2 REED SWITCH (BULLETIN M100.22)



NO.	NAME OF PART	MATERIAL	REMARKS
1	STANDPIPE		
2	FLANGE, SOCKET WELD		
3	FLANGE, THREADED		
4	CAP		
5	FLOAT		
6	PLUG		
7	STUD		
8	HEAVY HEX NUT		
9	PROCESS CONNECTION		
10	GASKET		
11	INDICATOR		
12	PIPET		
			•



## **SECTION A-A**

NOTE: AS STANDARD, PROCESS CONNECTIONS WILL BE ORIENTED AT 0°. THEY ARE SHOWN IN THIS DRAWING AT 90° FOR EASE OF VIEWING.

OPERATING CONDITIONS				
MAX PRESSURE				
MAX TEMPERATURE				
MIN SPECIFIC GRAVITY				
PROCESS FLUID				

OPERATING CONDITIONS				
	MAX PRESSURE			
	MAX TEMPERATURE			
	MIN SPECIFIC GRAVITY			
	PROCESS FLUID			

		16633 FOLTZ PARKWAY
DELETE LEVELSTAR, "II" NOTATION	l	STRONGSVILLE, OH 44149 USA
METRIC SCALE TO M/MM, MTII4200 TO 4300	JLI	(440) 572-1500   www.clarkreliance.com
REVISION	ВҮ	© Clark-Reliance® Corporation. All Rights Reserved.

4/30/2018

DATE

MANUFACTURED BY Clark·Reliance® 16633 FOLTZ PARKWAY STRONGSVILLE, OH 44149 USA

**JERGUSON®** MODEL MIIH-ST **MAGNICATOR** (W/ 600-2500# ANSI/ASME FLANGES)

	DRAWN: TJB	
	снескеd: <b>МК</b>	
	DATE: 4/8/2013	
	REVISION: 4	
	DRAWING NO.:	REV.:
	MIIH-ST6	4