GENERAL NOTES:

1. DIMENSIONS

- SHOWN IN INCHES W/ MM EQUIVALENTS IN BRACKETS
- OVERALL LENGTH = CENTERS + FLOAT LENGTH + MATING FLANGE THICKNESS + 6.063" [154]

2. OPERATING CONDITIONS

 MAX PRESSURE, MAX TEMPERATURE, & MIN SPECIFIC GRAVITY REQUIRED FOR PROPER GAGE DESIGN

3. PART NUMBER

• CONSULT "MAGNICATOR® MAGNETIC LIQUID LEVEL INDICATION PRODUCTS" (BULLETIN M100.01) FOR COMPLETE PART NUMBER DETAILS & LIST OF AVAILABLE OPTIONS

4 STANDPIPE SIZ

- 2 1/2" [65] SCH. 40 (STANDARD)
- CONSULT FACTORY FOR OPTIONAL STANDPIPE SIZE AND/OR SCHEDULE (DEPENDENT ON OPERATING CONDITIONS)

5. MATERIALS OF CONSTRUCTION

- 304/304LSS W/ CS TRIM (CAP, FLANGES, BOLTING, & PLUGS) (STANDARD)
- 316/316LSS W/ CS TRIM (CAP, FLANGES, BOLTING, & PLUGS) (STANDARD)
- ALL 304/304LSS (316SS BOLTING) (STANDARD)
- ALL 316/316LSS (316SS BOLTING) (STANDARD)
- CONSULT "MAGNICATOR® MAGNETIC LIQUID LEVEL INDICATION PRODUCTS" (BULLETIN M100.01) FOR A COMPLETE LIST OF AVAILABLE MATERIALS

6. FLOAT MATERIALS

- 316LSS (STANDARD)
- TITANIUM (STANDARD)
- MONEL 400
- HASTELLOY C276

7. FLOAT LENGTHS

- 12" [305] (STANDARD)
- 17" [432] (STANDARD)
- 22" [559] (STANDARD)
- LENGTHS DEPENDENT ON OPERATING CONDITIONS
- CONSULT FACTORY FOR CUSTOM LENGTHS

8. GASKET MATERIALS

- GARLOCK IFG5500 (MAX TEMPERATURE ≤ 550°F) (STANDARD)
- GRAFOIL® (MAX TEMPERATURE > 550°F) (STANDARD)
- CONSULT FACTORY FOR OPTIONAL GASKET MATERIALS

9. PROCESS CONNECTIONS

- ½" [15] THRU 1" [25] FSW & MSW (STANDARD)
- $\bullet~1~1\!\!/\!\!2^{\prime\prime}$ [40] THRU 6" [150] FSW & MSW AVAILABLE ON REQUEST
- (REQUIRE FITTINGS THAT INCREASE SECTION A-A DIMENSION SHOWN)
- (2) SIDE CONNECTIONS (STANDARD)
- (2+) SIDE CONNECTIONS AVAILABLE ON REQUEST

10. VENT / DRAIN CONNECTIONS

- ½" [15] FNPT (SHOWN) (STANDARD)
- 1/2" [15] THRU 1 1/2" [40] FNPT, MNPT, FSW, & MSW
- 1/2" [15] TO 3" [80] RAISED-FACE ANSI/ASME & DIN FLANGED

11. INDICATION

- YELLOW / BLACK FLAGS IN ALUMINUM HOUSING (SHOWN) (STANDARD)
- HERMETICALLY-SEALED FLAGS IN POLYCARBONATE TUBE W/ 316SS FRAME (BULLETIN M100.110)
- HERMETICALLY-SEALED FLAGS IN GLASS TUBE W/ 316SS FRAME (BULLETIN M100.110)
- NIGHTSTAR™ (ILLUMINATED FLAGS) (120 OR 240 VAC)(BULLETIN M100.140)

12. SCALES


- FEET / INCHES (SHOWN) (STANDARD)
- METER / MILLIMETER
- PERCENT
- CONSULT FACTORY FOR SPECIAL SCALES

13. POINT LEVEL SWITCHES


- SAS-16 TRI-MAGNET (BULLETIN M100.27)
- RS-2 (SPDT) HERMETICALLY-SEALED REED (BULLETIN M100.20)
- RS-2/2 (DPDT) HERMETICALLY-SEALED REED (BULLETIN M100.20)

14. 4-20mA TRANSMITTERS

- MTII-4300 MAGNETOSTRICTIVE (BULLETIN M100.23)
- RST2 REED SWITCH (BULLETIN M100.22)



| BILL OF MATERIAL | | | | | | | |
|------------------|--------------------|----------|---------|--|--|--|--|
| NO. | NAME OF PART | MATERIAL | REMARKS | | | | |
| 1 | STANDPIPE | | | | | | |
| 2 | FLANGE, SLIP-ON | | | | | | |
| 3 | FLANGE, THREADED | | | | | | |
| 4 | CAP | | | | | | |
| 5 | FLOAT | | | | | | |
| 6 | PLUG | | | | | | |
| 7 | STUD | | | | | | |
| 8 | HEAVY HEX NUT | | | | | | |
| 9 | PROCESS CONNECTION | | | | | | |
| 10 | GASKET | | | | | | |
| 11 | INDICATOR | | | | | | |
| | | | | | | | |



SECTION A-A

NOTE: AS STANDARD, PROCESS CONNECTIONS WILL BE ORIENTED AT 0°. THEY ARE SHOWN IN THIS DRAWING AT 90° FOR EASE OF VIEWING.

| OPERATING CONDITIONS | | |
|----------------------|--|--|
| MAX PRESSURE | | |
| MAX TEMPERATURE | | |
| MIN SPECIFIC GRAVITY | | |
| PROCESS FLUID | | |
| | | |



| Γ | | 4/30/2018 | DELETE LEVELSTAR, "II" NOTATION | ٦ | |
|---|-----------|--|---------------------------------|----|--|
| 1 | 4/30/2016 | METRIC SCALE TO M/MM, MTII4200 TO 4300 | JLI | | |
| Γ | REV | DATE | REVISION | BY | |

MANUFACTURED BY

Clark·Reliance®

16633 FOLTZ PARKWAY

STRONGSVILLE, OH 44149 USA

(440) 572-1500 | www.clarkreliance.com

© Clark-Reliance® Corporation. All Rights Reserved.

MODEL MIIH-SW MAGNICATOR (W/ 150-300# ANSI/ASME FLANGES)

JERGUSON®

| DRAWN: TJB | | |
|----------------|-------|--|
| CHECKED: MK | | |
| DATE: 4/8/2013 | | |
| REVISION: 1 | | |
| DRAWING NO.: | REV.: | |
| MIIH-SW1 | 1 | |